

## Product: AC Powerwall, Model #: 1108572, 1108567, 1092170 and 2012170

## **Manufacturers Declaration of Conformity**

Tesla Inc. certify and declare under their sole responsibility that the above referenced product, do not use Rate of Change of Frequency (RoCoF) protection or Vector Shift protection techniques for Loss of Mains detection, and comply with frequency and voltage requirements, to perform the tripping and disconnection from the grid when the following specification is applied:

G59 Issue 3 – Amendment 1

Engineering Recommendation G59 Issue 3 Amendment 1 August 2014 – Recommendations for the Connection of Generating Plant to the Distribution Systems of Licensed Distribution Network Operators.

G59 Issue 3 – Amendment 2

Engineering Recommendation G59 Issue 3 Amendment 2 September 2015– Recommendations for the Connection of Generating Plant to the Distribution Systems of Licensed Distribution Network Operators.

G59 Issue 3 – Amendment 3

Engineering Recommendation G59 Issue 3 Amendment 3 February 2018– Recommendations for the Connection of Generating Plant to the Distribution Systems of Licensed Distribution Network Operators.

G59 Issue 3 – Amendment 4

Engineering Recommendation G59 Issue 3 - Amendment 4 July 2018 – Recommendations for the Connection of Generating Plant to the Distribution Systems of Licensed Distribution Network Operators.

G59 Issue 3 – Amendment 7

Engineering Recommendation G59 Issue 3 - Amendment 7 September 2019 – Recommendations for the Connection of Generating Plant to the Distribution Systems of Licensed Distribution Network Operators.

\_12/7/2021\_\_\_\_\_(mm/dd/yyyy)

**Viraj Andrabadu** Manager, Compliance Engineering

Date

