



Technical Specification 41-37

Issue 2 2015

Switchgear for use on 66 kV to 132 kV
distribution systems

Part 4 Disconnectors and earthing switches

PUBLISHING AND COPYRIGHT INFORMATION

© 2015 *Energy Networks Association*

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system or transmitted in any form or by any means, electronic, mechanical, photocopying, recording or otherwise, without the prior written consent of Energy Networks Association. Specific enquiries concerning this document should be addressed to:

**Operations Directorate
Energy Networks Association
6th Floor, Dean Bradley House
52 Horseferry Rd
London
SW1P 2AF**

This document has been prepared for use by members of the Energy Networks Association to take account of the conditions which apply to them. Advice should be taken from an appropriately qualified engineer on the suitability of this document for any other purpose.

First published, September 2004

Revised, 2015

Amendments since publication

Issue	Date	Amendment
Issue 2	2015	Major revision. This issue includes the following principal technical changes. Details of all other technical, general and editorial amendments are included in the associated Document Amendment Summary for this Issue (available on request from the Operations Directorate of ENA).

Contents

Foreword.....	6
1 General.....	7
1.1 Scope	7
1.2 Normative references.....	7
2 Normal and special service conditions	7
2.2.1 Altitude.....	7
2.2.2 Pollution	7
2.2.3 Temperature and humidity	7
2.2.100Flood resilience.....	7
3 Terms and definitions.....	8
4 Ratings	8
4.1 Rated voltage (U_r).....	8
4.1.2 Range II for rated voltages above 245 kV	8
4.2 Rated insulation level (U_p).....	8
4.3 Rated frequency (f_r).....	8
4.5 Rated short-time withstand current (I_k)	8
4.8 Rated supply voltage of closing and opening devices and of auxiliary and control circuits (U_a).....	8
4.104Rated values of the bus-transfer current switching capabilities of disconnectors.....	9
4.105Rated values of the induced current switching capabilities of earthing switches.....	9
4.105.1Induced current switching.....	9
4.105.2Temperature rise.....	9
4.106Rated values of mechanical endurance for disconnectors.....	9
4.108 Earthing switches having a rated short circuit making current	9
5 Design and construction.....	9
5.1 Requirement for liquids in disconnectors and earthing switches.....	9
5.2 Requirement for gases in disconnectors and earthing switches	9
5.3 Earthing of disconnectors and earthing switches	10
5.4.100Auxiliary switches.....	10
5.4.101Loss of control supply	11
5.4.102Control circuit.....	12
5.4.102.1 Opening circuit	12
5.4.102.2 Closing circuit.....	13
5.5 Dependant power operation.....	14
5.6 Stored energy operation	14
5.7 Independent manual operation.....	14
5.7.200Operating handles for independent manually operated mechanisms	14
5.7.201Dedicated operating handle	14
5.8 Operation of releases.....	14
5.9.100Gas monitoring and indicators.....	14

5.10	Nameplates.....	14
5.11	Interlocking devices and padlocking facilities	14
5.11.107	AIS disconnecter and earthing switch interlocking	14
5.11.108	Key operated interlocking	15
5.11.109	Mechanical interference device withstand force.....	15
5.11.110	Drive system mechanical interference device	15
5.11.111	Interlock key release position.....	15
5.11.112	'Lockout' interlocks keys AIS disconnectors.....	15
	Provision shall be made to provide 'lockout' interlock keys on all disconnectors. These keys shall only be released when the disconnecter is in the open position. Lockout keys shall be distinctively labelled and shall each have a different 'differ' (term used to describe an individual key) to other keys in use on the substation site. The 'differ' shall also be different to that of other keys associated with the mechanism.	15
5.11.113	15
	Time delay for magnetic bolts	15
5.12	Position indication.....	15
5.13	Degrees of protection of enclosures.....	15
5.13.1	Protection of persons against access to hazardous parts and protection of the equipment against ingress of solid foreign objects	15
5.14	Creepage distances	15
5.14.100	Pollution performance.....	16
5.18	Electromagnetic compatibility (EMC)	16
5.19	X-ray emission	16
5.101	Height for operation and inspection.....	16
5.110	Bushing terminals	17
5.111	Moving parts	17
5.114	Foundation arrangements	17
5.114	Height for operation	17
5.201	Requirements in respect of the isolating distance of disconnectors.....	17
5.202	Mechanical strength.....	17
5.203	Maximum force required for manual operation	17
5.204	Pole operation.....	17
5.205	Operations counter.....	17
5.206	Manual operation of motor operated disconnectors with bus-transfer capability.....	18
6	Type tests	18
6.1	General.....	18
6.1.2	Information for identification of specimens	18
6.2.7	Tests of switchgear and control gear of $U_r > 245$ kV	18
6.2.8	Artificial pollution tests for outdoor insulators.....	18
6.3	Radio interference voltage (r.i.v.) test.....	18
6.4	Measurement of the resistance of circuits	19
6.5	Temperature-rise tests	19

6.5.100	Measurement of the surface temperature.....	19
6.6	Short-time withstand current and peak withstand current tests	19
6.6.1.102	Disconnectors and earthing switches with rated voltages of below 52 kV.....	19
6.6.1.103	Disconnectors and earthing switches with rated voltages of 52 kV and above	19
6.8	Tightness tests.....	19
6.104	Operation at temp limits	20
6.200	Solar radiation.....	20
7	Routine tests.....	20
7.2	Dielectric tests on auxiliary and control circuits	20
8	Guide to the selection of disconnectors and earthing switches.....	21
10	Rules for transport, storage, installation, operation and maintenance	21
11	Safety	21
12	Influence of the product on the Environment	21
13	Commissioning tests.....	21
Annex A (normative)	Self-Certification Conformance Declaration.....	22
Annex B (normative)	Summary of range, technical requirements and ratings for disconnector and earthing switch requirements.....	38

Figures

Figure 1 — Auxiliary switch position in relation to the primary contacts	11
--	----

Foreword

This Technical Specification (TS) is published by the Energy Networks Association (ENA) and comes into effect from date of publication. It has been prepared under the authority of the ENA Engineering Policy and Standards Manager and has been approved for publication by the ENA Electricity Networks and Futures Group (ENFG). The approved abbreviated title of this engineering document is “ENA TS 41-37 Part 4”.

This document replaces and supersedes Technical Specification 41-37 Issue 1 2004.

This Technical Specification has been prepared by the Energy Networks Association.

ENA TS 41-37 is a suite of engineering documents that sets out ENA Member Company requirements for specification of switchgear for use on 66 kV to 132 kV distribution systems. ENA TS 41-37 is a multi-part document comprising of the following parts.

- Part 1 – Common clauses
- Part 2 – Gas-insulated metal-enclosed switchgear
- Part 3 – Alternating current circuit-breakers
- Part 4 – Disconnectors and earth switches
- Part 5 – Inductive voltage transformers, capacitor voltage transformers, combined unit transformers and current transformers for use on 72.5 kV to 145 kV distribution systems
- Part 6 – Disconnecting circuit breaker with an integral earthing switch for use at 72.5 kV and 145 kV distribution systems

Switchgear covered by this Technical Specification shall conform to the latest issues of the relevant International and British Standards listed. This Technical Specification amplifies and/or clarifies the requirements of those Standards, where alternative arrangements are permitted and where additional information is required.

This specification should be read in conjunction with the relevant International and British Standards, and to assist in cross-reference, the document follows the format of the major International Standards. Where possible, the International Standards' clause numbers have been used preceded with the number of the relevant part of this specification.

The Electricity at Work Regulations 1989 made under the Health and Safety at Work Act 1974, apply to switchgear whenever manufactured, purchased or installed. Appendix 2 of the Memorandum of guidance on the Regulations lists Standards, Codes of Practice and other publications which contain guidance relevant to the Regulations and electrical safety.

Part 1 of the document covers all common clause requirements of switchgear, as defined. This document covers all additional clauses required by the ENA in order to fulfil the requirements of ENA conformance.

Annex A, of the document is the 'Self Certification Conformance Declaration' sheets for the equipment. Annex B, is a summary of range, technical requirements and ratings for each type of equipment for completion by the Purchaser.

1 General

The common clauses (Part 1) of this specification, and the requirements of International Standard IEC 62271-102 apply except where modified by the following clauses.

1.1 Scope

This specification defines technical requirements for switchgear rated at voltages within the range 72.5kV to 145 kV and applies to alternating current switchgear, designed for indoor or outdoor installation, cable or overhead conductor connected, and for operation at service frequency of 50 Hz on systems having voltages at 66kV and up to and including 132 kV.

Equipment covered by this specification is for use on systems with the neutral point earthed solidly, or effectively earthed through a resistor or reactor.

This specification only includes the additional clauses that apply to disconnectors and earthing switches specified by ENA Member Companies, which are in addition to the requirements of IEC 62271-102.

1.2 Normative references

The following referenced documents, in whole or part, are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

Standards publications

IEC 62271-1, *High-voltage switchgear and controlgear – Part 1: Common specifications*

IEC 62271-102, *High-voltage switchgear and controlgear – Part 102: Alternating current disconnectors and earthing switches*

Other publications

[N1] ENA TS 41-37 Part 1, *Switchgear for use on 66 kV to 132 kV distribution systems – Common clauses*

[N2] ENA TS 98-1, *Environmental classification and corrosion protection of structures, plant and equipment*

2 Normal and special service conditions

Clauses 2 to 2.1.2 inclusive of ENA TS 41-37 Part 1 [N1] and of IEC 62271-1 shall apply.

2.2 Special service conditions

2.2.1 Altitude

Clause 2.2.1 of ENA TS 41-37 Part 1 [N1] and of IEC 62271-1 shall not apply.

2.2.2 Pollution

Clause 2.2.2 of ENA TS 41-37 Part 1 [N1] shall apply.

2.2.3 Temperature and humidity

Clauses 2.2.3 to 2.2.6 inclusive of ENA TS 41-37 Part 1 [N1] and of IEC 62271-1 shall apply.

2.2.100 Flood resilience

Clause 2.2.100 of ENA TS 41-37 Part 1 [N1] shall apply.

3 Terms and definitions

Clause 3 to 3..7.123 of IEC 62271-102 shall apply.

4 Ratings

Clause 4 of ENA TS 41-37 Part 1 [N1] and IEC 62271-102 shall apply.

4.1 Rated voltage (U_r)

Clause 4.1 of ENA TS 41-37 Part 1 [N1] shall apply.

4.1.1 Range I for rated voltages of 245 kV and below

Clause 4 1.1 of IEC 62271-1 is applicable

4.1.2 Range II for rated voltages above 245 kV

Clause 4 1.2 of IEC 62271-1 is not applicable.

4.2 Rated insulation level (U_p)

Clause 4.2 of ENA TS 41-37 Part 1 [N1] shall apply.

4.3 Rated frequency (f_r)

Clause 4.3 of ENA TS 41-37 Part 1 [N1] shall apply.

4.4 Rated normal current and temperature rise

Clause 4.4 to 4.4.3 inclusive of IEC 62271-1 shall apply

4.5 Rated short-time withstand current (I_k)

Clauses 4.5 of ENA TS 41-37 Part 1 [N1] and clause 4.5 of IEC62271-102 shall apply.

4.6 Rated peak withstand current

Clause 4.6 of IEC 62271-102 shall apply

4.7 Rated duration of short circuit

Clause 4.7 of IEC 62271-102 shall apply

4.8 Rated supply voltage of closing and opening devices and of auxiliary and control circuits (U_a)

Clauses 4.8 to 4.8.3 inclusive of ENA TS 41-37 Part 1 [N1] shall apply.

4.9 Rated supply frequency of closing and opening devices and of auxiliary circuits

The standard values of rated supply frequency is DC. ..

4.10 Rated pressure of compressed gas supply for controlled pressure systems

Sub-clauses 4.10 and 4.11 of IEC 62271-1 shall apply.

4.101 Rated short-circuit making current

Clause 4.101 of IEC 62271-102 shall apply