



Technical Specification 43-125

Issue 2 2017

Design guide and technical specification for
overhead lines above 45 kV

Part 2 Conductor systems, insulators and fittings

PUBLISHING AND COPYRIGHT INFORMATION

© 2017 *Energy Networks Association*

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system or transmitted in any form or by any means, electronic, mechanical, photocopying, recording or otherwise, without the prior written consent of Energy Networks Association. Specific enquiries concerning this document should be addressed to:

**Operations Directorate
Energy Networks Association
6th Floor, Dean Bradley House
52 Horseferry Rd
London
SW1P 2AF**

This document has been prepared for use by members of the Energy Networks Association to take account of the conditions which apply to them. Advice should be taken from an appropriately qualified engineer on the suitability of this document for any other purpose.

Issue 1 of TS 43-125 published, 2005

Revised, 2017

Amendments since publication

Issue	Date	Amendment
Issue 2	February 2017	<p>Issue 1 major revision:</p> <ul style="list-style-type: none">(i) reflects major technical amendments made to two main Standards referenced namely BS EN 50341-1 and BS EN 50341-2-9(ii) split the document into multi-parts reflecting standalone design requisites and the requirements for individual components and parts of lattice tower design(iii) remove wood poles and steel poles from the scope of TS 43-125.(iv) remove requirements covering optical fibre cable as this topic is covered by ENA TS 43-126.. <p>TS 43-125 has been divided into 4 separate documents:</p> <ul style="list-style-type: none">• Part 1 Design basis and electrical requirements• Part 2 Conductor systems, insulators and fittings• Part 3 Vibration dampers and spacers• Part 4 Foundations and site requirements <p>Clause numbering of this Specification has changed significantly due to the document becoming 4 Parts. The cross referencing within the document has been updated accordingly.</p>

	<p>To ensure consistency to the normative reference BS EN 50341 throughout the document, the following key changes have been completed.</p> <ul style="list-style-type: none"> • Where BS EN 50341-1 Part 1 and Part 2-9 are referenced in square brackets as part of the clause title, these references have been amended to ensure all are correct and accurate. • All references to 'Part 3' have been changed to the correct 'Part 2-9' reference as appropriate. • The terminology to describe the design approaches has been amended throughout i.e. <ul style="list-style-type: none"> i. 'General Approach' is now written as 'Approach 1' ii. 'Empirical Approach' is now written as 'Approach 3' <p>NOTE: To avoid confusion due to the extensive re-numbering of existing Clauses and addition of new Clauses, the Clause numbering below refers to this revised version, Issue 2. The Clause numbers of Issue 1 are given in brackets, where relevant.</p> <p>The following technical changes are relevant to this document.</p> <p>'Foreword' Clause updated. New paragraph 5 and 6 inserted to replace and complement previous paragraphs describing importance of BS EN 50341. Paragraph 9 has been amended to describe the splitting of TS 43-125 into 4 Parts. Explanation added of the structure of each document.</p> <p>Clause 1.1.2: The description of the normative Standards has been changed to Part 1 and Part 2 only.</p> <p>Issue 1 Clause 2, Quality Assurance: This Clause has been moved to Clause 1.4 under the main Introduction Clause. Issue 1 Clause 2.5 has been deleted as it replicates the requirements in BS EN 50341-1. The previous annexes in Issue 1 Clause 2 have been deleted.</p> <p>Issue 1, Clause 5 (Conductor Systems) now numbered as Clause 2.</p> <p>Clause 2.3 (Issue 1, Clause 5.3), Normative references: References updated and new Standards added as appropriate.</p> <p>Issue 1, Clause 5.3.6 (Empirical Approach - Sagging bases). Clause deleted as empirical approach not applicable to lattice tower design.</p> <p>Clause 2.7.10.3 (Issue 1, Clause 5.7.10.3). New Figure 2.1 inserted taken from ENA TS 43-6 'Drawing 430608' as referred to in previous issue of TS 43-125.</p> <p>Clause 2.8.3.2 (Issue 1, Clause 5.8.3.2). Minor amendment to reference in BS EN 50189.</p> <p>Clause 2.8.4 (Issue 1, Clause 5.8.4): Reference to BS EN 50326 Table 1 inserted.</p> <p>Issue 1, Clause 7 (Insulators and insulator sets) now numbered as Clause 3.</p> <p>Clause 3.3 (Issue 1, Clause 7.3), Normative references: References updated and new Standards added as appropriate.</p> <p>Clause 3.4.1.3 (Issue 1, Clause 7.4.1.3). Reference to BS EN 61952 and the upcoming IEC 61952-1, inserted in commentary for composite line post insulators.</p> <p>Table 3.1 (Issue 1, Table 7.1). Column for 66 kV inserted.</p> <p>Clause 3.4.4 (Issue 1, Clause 7.4.4). Reference to ENA TS 43-93 inserted and description of creepages generally aligned with TS 43-93. Previous Table 7.2 deleted.</p> <p>Clause 3.4.7 (Issue 1, Clause 7.4.7). Reference to the 'empirical approach' deleted in Table 3.3.</p>
--	---

PUBLISHING AND COPYRIGHT INFORMATION

		<p>Clause 3.4.8 (Issue 1, Clause 7.4.8). Reference to HD 474 S1 replaced with BS 3288-3.</p> <p>Clause 3.4.10 (Issue 1, Clause 7.4.10) Guy Insulators - clause deleted as poles are outside scope of TS 43-125 and hence guys are not relevant.</p> <p>New Clause 3.5.3 added to include high level description of composites.</p> <p>Clause 3.9.1 (Issue 1, Clause 7.9.1). Reference to Part 1 and Part 2 of BS EN 60383 inserted. New reference to BS EN 61952 inserted. New reference to IEC TR 62370.</p> <p>Clause 3.9.5 (Issue 1, Clause 7.9.5). Reference to BS EN 61211 replaced with BS EN 7803.</p> <p>Clause 3.9.8 (Issue 1, Clause 7.9.8). Reference to BS EN 61109 replaced with BS EN 61952.</p> <p>Clause 3.9.10.3 (issue 1, 7.9.10.3). Reference to BS EN 60060-1 inserted. Requirements for RIV and Corona testing clarified and generally aligned with ENA TS 43-93.</p> <p>Clause 3.9.12 (Issue 1, Clause 7.9.12). BS EN 61467 corrected to BS EN 61647.</p> <p>Issue 1, Clause 8 (Insulators and insulator sets) now numbered as Clause 4.</p> <p>Clause 4.3 (Issue 1, Clause 7.3), Normative references: References updated and new Standards added as appropriate.</p> <p>Clause 4.4.2 (Issue 1, Clause 8.4.2). Reference to HD 474-S1 replaced by BS EN 3288-3.</p> <p>Clause 4.4.3 (Issue 1, Clause 8.4.3). Reference to the 'empirical approach' deleted in Table 4.1.</p> <p>Clause 4.4.6.2 (Issue 1, Clause 8.4.6.2). Reference to BS 464 replaced by BS EN 13411-1.</p> <p>Clause 4.5 (Issue 1, Clause 8.5). Reference to BS 1387 replaced by BS EN 10255.</p> <p>Clause 4.4.5.1 (Issue 1, Clause 8.4.5.1). Previous commentary deleted.</p> <p>Clause 4.9.1 (Issue 1, Clause 8.9.1). Reference to Issue 1 Section 6 replaced with ENA TS 43-126 Parts 1-4.</p> <p>Clause 4.9.5.2 (Issue 1, Clause 8.9.5.2). Guidance for suspension clamp tests involving fibre optics replaced with reference to ENA TS 43-126 Parts 1-4.</p> <p>Clause 4.9.6.2 (Issue 1, Clause 8.9.6.2). Guidance for tension clamp tests involving fibre optics replaced with reference to ENA TS 43-126 Parts 1-4.</p> <p>Bibliography added. Non-Normative references contained in the Specification included.</p> <p>Details of all other technical, general and editorial amendments are included in the associated Document Amendment Summary for this Issue (available on request from the Operations Directorate of ENA).</p>
--	--	---

Contents

1	Introduction	13
1.1	Scope	13
1.1.1	General [Part 1 Clause 1, Part 2-9 Clause 1]	13
1.1.2	BS EN 50341 [Part 1 Introduction & Clause 1]	13
1.1.3	National Normative Aspects [Part 1 Introduction, Part 2-9 Foreword]	13
1.1.4	Existing Energy Network Association Technical Specifications	13
1.2	Definitions [Part 1 Clause 2.2].....	14
1.3	Normative references [Part 1 Clause 2.1, Part 2-9 Clause 2.1]	14
1.3.1	General	14
1.3.2	European pre-standards (ENVs)	14
1.4	Quality assurance [Part 1 Clause 12].....	14
1.4.1	Quality assurance terms.....	14
1.4.2	Quality assurance programme	15
1.4.3	Related standards.....	15
1.4.4	Quality control	16
1.4.4.1	Inspection and Testing.....	16
1.4.5	Type, Sample and Routine Tests	16
1.4.6	Non-Conforming products	16
1.4.7	Monitoring of Quality Assurance Agreements.....	16
1.4.8	Suppliers and Subcontractor	16
1.4.9	Method statements.....	16
2	Conductor systems	18
2.1	Scope [Part 1 Clause 9]	18
2.2	Terms and definitions [Part 1 Clause 2]	18
2.3	Normative references.....	19
2.3.1	General.....	19
2.3.2	Bundle configuration	20
2.3.3	Electrical requirements [Part 1 Clause 9.2.2, Clause 9.3.2 and Clause 9.5.2].....	20
2.3.4	Conductor service temperature [Part 1 Clause 9.2.3, 9.3.3 and Clause 9.5.3].....	20
2.3.5	Ultimate limit state sagging bases – Approach 1	21
2.3.6	Design submissions	22
2.4	Materials	23
2.4.1	Conductors [Part 1 Clauses 9.2.1, 9.3.1 and 9.5.1]	23
2.4.2	Conductor grease	23
2.4.3	Conductor Drums	24
2.5	Corrosion protection [Part 1 Clauses 9.2.5 and 9.3.5.]	24
2.6	Workmanship.....	24
2.6.1	General.....	24
2.6.2	Conductor grease	24
2.7	Conductor stringing.....	25

2.7.1	General	25
2.7.2	Conductor stringing - method statement	25
2.7.3	Conductor lengths and joints	25
2.7.4	Conductor stringing	25
2.7.4.1	General [Part 1 Annex N.4]	25
2.7.4.2	Conductor hauling devices	26
2.7.4.3	Stringing blocks	26
2.7.4.4	Support backstaying	26
2.7.4.5	Conductor stringing platforms	26
2.7.4.6	Conductor sagging	26
2.7.4.7	Clamping-in	27
2.7.4.8	Safety	27
2.7.5	Crossing of obstacles	27
2.7.6	Repair sleeves	28
2.7.7	Conductor preparation and jointing	28
2.7.7.1	Conductor cutting	28
2.7.7.2	Conductor jointing	28
2.7.8	Attachment of conductor fittings	28
2.7.8.1	Surface greasing of conductors	28
2.7.8.2	Greasing of bolted interfaces	28
2.7.8.3	Vibration dampers	28
2.7.8.4	Spacers and spacer dampers	28
2.7.8.5	Bird flight diverters and line markers	29
2.7.9	Tension support jumpers	29
2.7.10	Earthwire bonds	30
2.7.10.1	Suspension supports	30
2.7.10.2	Angle and section supports	30
2.7.10.3	Terminal supports	30
2.7.10.4	Earthwire changeover supports and junction supports	31
2.7.11	Downleads	31
2.7.12	Line terminations	32
2.8	Quality assurance	32
2.8.1	General	32
2.8.2	Conductor manufacture	32
2.8.3	Conductor - type, sample and routine tests [Part 1 Clause 9.7]	32
2.8.3.1	Type tests	32
2.8.3.2	Sample tests	32
2.8.3.3	Routine inspection	33
2.8.4	Conductor grease - type and sample tests	33
2.8.4.1	Type tests	33
2.8.4.2	Sample tests	33
2.8.11	Test certificates and installation records	34
3	Insulators and insulator sets	39
3.1	Scope [Part 1 Clause 10]	39

3.2	Terms and definitions [Part 1 Clause 2]	39
3.3	Normative references.....	39
3.4	Design [Part 1 Clause 10.1 and Annex Q.1 and Q.2]	40
3.4.1	General	40
3.4.1.1	Characteristics of insulator units and insulator sets [Part 1 clause 10.10].....	40
3.4.1.2	Service conditions	41
3.4.1.3	Zinc sleeves [Part 1 Clause 10.8.4]	41
3.4.2	Electrical requirements [Part 1 Clause 10.2].....	42
3.4.3	Radio interference voltage (RIV) requirements and corona extinction voltages [Part 1 clause 10.3]	42
3.4.4	Pollution performance requirements [Part 1 Clause 10.4].....	42
3.4.5	Power arc requirements [Part 1 Clause 10.5].....	43
3.4.6	Audible noise requirements [Part 1 Clause 10.6].....	43
3.4.7	Mechanical requirements [Part 1 Clause 10.7 and Part 2-9 Table 4.13.1/GB.2].....	43
3.4.8	Couplings [Part 2-9 Clause 10.10].....	44
3.4.9	Insulator protective devices.....	44
3.5	Materials [Part 1 Clause 10.9].....	45
3.5.1	General	45
3.5.2	Zinc sleeves	45
3.5.3	Composites	45
3.6	Workmanship.....	45
3.7	Corrosion Protection [Part 1 clause 10.8.1 and 10.8.3]	46
3.8	Installation [Part 1 Annex Q.4]	46
3.8.1	Installation criteria	46
3.8.2	Erection.....	46
3.9	Quality Assurance [Part 1 Clause 10.11, 10.12 and 10.13]	48
3.9.1	General.....	48
3.9.2	Identification and marking	49
3.9.3	String insulator units and line post insulators – Type tests [Part 1 Clause 10.11.1].....	49
3.9.4	String insulator units – Residual strength type tests [Part 1 Clause 10.11.2].....	49
3.9.5	String insulator units – Impulse voltage puncture type tests [Part 1 Clause 10.11.2].....	49
3.9.6	String insulator units – Zinc sleeve type tests [Part 1 Clause 10.11.2].....	49
3.9.7	Composite string insulator units – Type tests [Part 1 Clause 10.11.1].....	50
3.9.8	Composite line post insulators – Type tests [Part 1 Clause 10.11.1]	50
3.9.9	Insulator string sets – Type tests [Part 1 Clause 10.11.1].....	50
3.9.10	RIV and corona – Type tests [Part 1 Clause 10.11.2].....	51
3.9.10.1	General	51
3.9.10.2	Single unit test.....	51
3.9.10.3	Assembled insulator set test.....	51
3.9.11	Pollution performance – Type tests [Part 1 Clause 10.11.2].....	52

- 3.9.12 Power arc – Type tests [Part 1 Clause 10.11.2]53
- 3.9.13 Sample tests [Part 1 Clause 10.12].....53
- 3.9.14 Routine tests [Part 1 Clause 10.13].....53
- 3.9.15 Test certificates [Part 1 Clause 10.15].....53
- 3.9.16 Installation.....53
- 4 Insulator and conductor fittings58
 - 4.1 Scope [Part 1 Clause 11]58
 - 4.2 Terms and definitions [Part 1 Clause 2]58
 - 4.3 Normative references.....58
 - 4.4 Design [Part 1 Clause 11]59
 - 4.4.1 General [Part 1 Clause 11.1, 11.2, 11.3, 11.4, 11.5 and 11.6].....59
 - 4.4.2 Couplings [Part 1 Clause 11.9 and Part 2-9 Clause 10.10].....59
 - 4.4.3 Mechanical requirements [Part 1 clause 11.6 and Part 2-9 Table 4.13.1(b)/GB.2]60
 - 4.4.4 Insulator set and earthwire fittings.....60
 - 4.4.4.1 General60
 - 4.4.4.2 Live-line fittings.....60
 - 4.4.4.3 Sag adjusters61
 - 4.4.4.4 Low duty tension insulator sets.....61
 - 4.4.4.5 Tension insulator sets – earth end linkages.....61
 - 4.4.5 Suspension clamps.....61
 - 4.4.5.1 General61
- Bibliography90

Figures

- Figure 2.1 — Terminal support steelwork31

Tables

- Table 2.1 — Ultimate limit state sagging bases – Approach 1.....21
- Table 3.1 — Electrical withstand voltages42
- Table 3.2 — Partial strength factor (γ_m) – insulator units.....43
- Table 3.3 — Insulator units and insulator sets – Type and Sample tests48
- Table 3.4 — RIV test voltage, radio noise limit and corona extinction voltage52
- Table 4.1 — Partial strength factors (γ_m) – Insulator and conductor fittings.....60
- Table 4.2 — Insulator set and earthwire fittings – Type and Sample tests.....70
- Table 4.3 — Suspension clamps – Type and Sample tests71
- Table 4.4 — Tension joints and clamps – Type and Sample tests.....73
- Table 4.5 — Partial tension fittings – Type and Sample tests76
- Table 4.6 — Partial tension fittings – Type and Sample tests77
- Table 4.7 — Insulator protective fittings – Type and Sample tests.....78

Table 4.8 — Miscellaneous fittings – Type and Sample tests79

Foreword

This Technical Specification (TS) is published by the Energy Networks Association (ENA) and comes into effect from the date of publication. It has been prepared under the authority of the ENA Engineering Policy and Standards Manager and has been approved for publication by the ENA Electricity Networks and Futures Group (ENFG). The approved abbreviated title of this engineering document is “ENA TS 43-125”.

Energy Networks Association Technical Specifications (ENA TS) 43 series for Overhead Lines were originally issued as Electricity Supply Industry (ESI) Specifications, and reflected current practice within the industry in the 1970-80s. Design methodology was based on the deterministic approach in accordance with the requirements of the Electricity (Overhead Lines) Regulations 1970. Complementary design requirements were based on the CEGB Transmission Plant Standards, subsequently reissued as ENA Technical Specifications.

European Normalised Standard, EN 50341, for the general design requirements of overhead electrical lines, initially for lines with voltages exceeding 45 kV (a.c.) was published in 2001. To complement the main body of the Standard, National Normative Aspects (NNAs) were prepared to reflect existing national laws or regulations relating to the design and/or construction of overhead lines, climatic conditions and current national practices in their own country. BS EN 50341 and its associated NNA Standard became the main normative reference for overhead line design in the United Kingdom (UK) as reflected in ENA TS 43-125 Issue 1.

In 2012, BS EN 50341-1 (subsequently referred to as Part 1) was subject to a technical revision. Technical content was updated and the scope was widened to cover overhead lines exceeding 1 kV a.c. The technical changes in the document impacted a number of topics including overhead line loadings. For example, the move away from using hourly-mean wind speeds for calculating applied forces on overhead line structures to 10-minute mean wind speeds. The ENA conducted specialist analysis of impacts of the revised BS EN 50341-1 and, as such, calculation factors have been incorporated into the NNA, where appropriate, to mitigate onerous overhead line designs.

Following the revision of BS EN 50341-1, the UK NNA was revised and published in 2015 as BS EN 50341-2-9 (subsequently referred to as Part 2-9). The intent of the United Kingdom NNA remains the same in that minimum design loading conditions and corresponding ‘boxed’ values have been specified and reference made to the Project Specification for the actual conditions or values.

Previously, two distinct design approaches were described in BS EN 50341-1 for both the mechanical and electrical design: the ‘General Approach’ based on the application of probabilistic reliability theory and an ‘Empirical Approach’ based on long term European experience, i.e. a deterministic-based design. The revised Standard now describes Approaches 1-3. However, it is Approach 1 (previously ‘General Approach’) and Approach 3 (previously ‘Empirical Approach’) that are followed in the UK as declared in Part 2-9. Indicative values for partial loading or material factors (‘boxed’ values) are contained within the main body of the Standard, with the actual value specified in the NNA or alternatively in the Project Specification.

To ensure consistency in the application of both Part 1 and Part 2-9 and to provide guidance in the determination of the actual loading cases, boxed values etc., the Energy Networks Association has prepared this Specification for overhead lines above 45 kV, specifically, lattice tower overhead lines. ENA TS 43-125 Issue 1 contained requirements for wood pole and steel pole overhead lines but this has been removed as such construction is covered by other Engineering Documents, namely: ENA TS 43-30 [1], ENA TS 43-40 [2], ENA TS 43-50 [3] and ENA TS 43-97 [4].

Since neither Part 1 nor Part 2-9 encompass the installation aspects of overhead line construction, standard Clauses covering these requirements have been included at appropriate points. To further assist in the use of these technical guidance documents cross-references have been included in the Clause headings.

To provide guidance on the application of Part 1 and Part 2-9, where appropriate, a '*commentary*' has been provided in the text, especially as regards the determination of specific design loading conditions and the corresponding partial loading and material factors.

ENA TS 43-125 has been restructured as a multi-part document with the objective that any future amendments can be completed in an efficient and timely manner. ENA TS 43-125 comprises of the following parts.

ENA TS 43-125 Part 1 – Design basis and electrical requirements.

ENA TS 43-125 Part 2 – Conductor systems, insulators and fittings.

ENA TS 43-125 Part 3 – Vibration dampers and spacers.

ENA TS 43-125 Part 4 – Foundations and site requirements.

Within each Part of TS 43-125, the main Clause heading is used to bound the requirements for a particular topic, e.g. Clause 2 in ENA TS 43-125 Part 3 captures all requirements for vibration dampers. Under each main Clause, the scope, terms and definitions and normative references are provided, relevant to that topic.

Previous requirements in ENA TS 43-125 Issue 1 covering optical fibre cables have been removed as this topic is covered by ENA TS 43-126 suite of documents.

Project information to be provided by the ENA Member Company (ENAMC) Engineer, quality assurance requirements and the need for Contractors' and/or Suppliers' design submissions have been identified throughout this Specification. For consistency, informative annexes are included at the end of each main Clause heading and include the following details.

- Annex A: Project Information to be provided by the ENAMC Engineer.
- Annex B: Contractors' and/or Suppliers' Q.A. Hold and Notification Points.
- Annex C: Contractors' and/or Suppliers' Design Submissions.

Overhead lines by their very nature constitute a hazardous environment during their construction, maintenance and dismantling. Consequentially, to fulfil the requirements of the CDM Regulations [5] health and safety considerations and in particular 'risk assessments' should be undertaken as part of the overall design process.