

GPa_PGU_CM_rev.2



Product Certificate Number	20708-5-CER-E2	
Applicant	EPC Power Corp. 13250 Gregg Street Suite A-2 92064. Poway. California, USA	
Series	PD CAB1000	
Models	50-100205 (PD 250) 50-100144 (PD 250 HYDRA)	50-100195 (PD 500) 50-100100 (CAB1000/AC-2L.1)
Type of generating unit	Bidirectional Energy Storage & Microgrid PCS	
Technical Data	See pages 2 and 3.	
Software version	fea5619 (3.5.12)	
Network connection code/Standard	Engineering Recommendation G99, Issue 1 Amendment 6. March 2020. Requirements for the connection of generation equipment in parallel with public distribution networks on or after 27 April 2019. Type B, C and D.	

Having assessed the report number: 20708-5-TR performed by CERE (Accredited Laboratory N° 5314.01) and simulation report number 20708-5-S performed by CERE (Accredited Laboratory N° 5314.01) based on the requirements of the EN ISO/IEC 17025: 2017.

The above-mentioned generating unit complies with the requirements of the:

Engineering Recommendation G99, Issue 1 Amendment 6. March 2020. Requirements for the connection of generation equipment in parallel with public distribution networks on or after 27 April 2019. Type B, C and D.

This certification is according the CERE internal process PET-CERE-09 Rev 30 based on the requirements of the EN ISO/IEC 17065:2012. For this certification process the conformity assessment activities were based on:

- Testing of production samples selected by CERE.
- Audit of quality system according ISO 9001 with certificate number: 55241 issued by a certification body accredited according EN ISO/IEC 17021.
- Inspection of the manufacturing process.

This certificate cancels and supersedes the certificate number 20708-5-CER-E1 issued on March 05, 2021

Madrid, March 23, 2021. This certificate is valid until February 26, 2024

Miguel Martínez Lavin Certification Manager





Technical data

PD Series

50-100205 (PD250)				
AC				
AC voltage range	208-480 Vrms +10% / -12%			
AC export power @ 60Cº inlet (480Vrms)	250 kVA 301 Arms			
AC import power @ 55Co inlet (480 Vrms)	250 kVA 301 Arms			
Nominal frequency	50 Hz			
DC				
DC voltage range	350 – 1250 V			
Max. DC current	370 A			
Number of DC inputs	1			
Environmental				
Ambient temperature (operation)	-40°C to 50°C			
Ambient temperature (storage)	-40°C to 50°C			

50-100144 (PD250 HYDRA)				
AC				
AC voltage range	480 Vrms + 10% / -12%			
AC export power (@ 60Cº inlet)	250 kVA 30 <mark>1 Arm</mark> s			
AC import power (@ 55Co inlet)	250 kVA 301 Arms			
Nominal frequency	50 Hz			
DC				
Battery DC port	550 A 1250 V max 375 kW			
Solar DC port	550 A 200 – 620 V 250 kW			
Battery voltage range	710 – 1250 V			
Environmental				
Ambient temperature (operation)	-40°C to 50°C			
Ambient temperature (storage)	-40°C to 50°C			







50-100195 (PD500)				
AC				
AC port configuration	3-wire (3P3W)			
AC voltage range	208-480 Vrms + 10% / -12%			
AC export power @ 60Co inlet (480 Vrms)	500 kVA 602 Arms			
AC import power @ 55Cº inlet (480 Vrms)	500 kVA 602 Arms			
Nominal frequency	50 Hz			
DC				
DC voltage range	350 – 1250 V			
Max. DC current	750 A			
Number of DC inputs	1			
Environmental				
Ambient temperature (operation)	-40°C to 50°C			
Ambient temperature (storage)	-40°C to 50°C			


CAB1000 series

50-100100 (CAB1000/AC-2L.1)					
Lineup Quantity	1 4				
AC					
AC configuration	3-wire (3P3W)				
AC voltage range	208 - <mark>690</mark> Vrms + 10 <mark>% / -12</mark> %				
AC export power @ 40Co (480 Vrms)	1043 kVA 1255 Arms 4172kW 5020 Arms				
AC import capacity @ 40Co (4800 Vrms)	1043 kW 1255 Arms 4172kW 5020 Arms				
Nominal frequency	50 Hz				
DC					
DC voltage range	350 – 1250 V				
Battery voltage range	750 – 1000 V @ 480 Vrms				
Max. DC current	1400 A 5600 A				
Environmental					
Ambient temperature (operation)	-20°C to 40°C				
Ambient temperature (storage)	-40°C to 60°C				






Electrical Diagram of PD series



Electrical Diagram of CAB1000 series





GPa_PGU_CM_rev.2



The sample selected to test was representative of the

production. The sample was selected in:

EPC Power Corp.

13250 Gregg Street Suite A-2 92064. Poway. California, USA

Sample Report Number: 20708-TM

The inspection of manufacturing process was performed in:

On October 14th, 2020

EPC Power Corp.

13250 Gregg Street Suite A-2 92064. Poway. California, USA

Inspection Report Number: 20708-20-1-IF

RECORD OF CHANGES

Revision	Modification / Changes	Date
0	Initial version	26/02/2021
1	New edition due to editorial changes	05/03/2021
2	Elimination of two variant models due to changes in their configuration that affect to the compliance of the standard.	23/03/2021