


### FORM C TYPE TEST VERIFICATION REPORT

All Micro-generators connected to the **DNO Distribution Network** shall be **Fully Type Tested**. This form is the **Manufacturer's** declaration of compliance with the requirements of G98.

This form should be used when making a Type Test submission to the Energy Networks Association (ENA).Type Test Register.

If the **Micro-generator** is **Fully Type Tested** and already registered with the ENA **Type Test Register**, the **Installation Document** should include the **Manufacturer's** Reference Number (the system reference), and this form does not need to be submitted.

<b>Manufacturer's</b> reference number		Fronius Symo Advanced 10.0-3-M	
<b>Micro-generator</b> technology		transformerless	
<b>Manufacturer</b> name		Fronius International GmbH	
Address		Gunter Fronius Str 1 4600 Wels-Thalheim, Austria	
Tel	+43-7242-241-0	Fax	+43-7242-241-224
E:mail	p.v@fronius.com	Web site	<a href="http://www.fronius.com">www.fronius.com</a>
<b>Registered Capacity</b> , use separate sheet if more than one connection option.	Connection Option		
	--	kW single phase, single, split or three phase system	
	10,0	kW three phase	
	--	kW two phases in three phase system	
	--	kW two phases split phase system	
Energy storage capacity for <b>Electricity Storage</b> devices	--	kWh	
<b>Manufacturer</b> Type Test declaration. - I certify that all products supplied by the company with the above <b>Fully Type Tested</b> reference number will be manufactured and tested to ensure that they perform as stated in this document, prior to shipment to site and that no site modifications are required to ensure that the product meets all the requirements of EREC G98.			
Signed	 FRONIUS INTERNATIONAL GMBH Günter Fronius Str. 1 4600 Wels-Thalheim Tel: +43 / (0) 72 42 / 241-0, Fax: 47 8 25	On behalf of	Fronius International GmbH

Note that testing can be done by the **Manufacturer** of an individual component or by an external test house.

Where parts of the testing are carried out by persons or organisations other than the **Manufacturer** then that person or organisation shall keep copies of all test records and results supplied to them to verify that the testing has been carried out by people with sufficient technical competency to carry out the tests.

**Operating Range:** This test should be carried out as specified in A.1.2.10.

Pass or failure of the test should be indicated in the fields below (right hand side), for example with the statement "Pass", "No disconnection occurs", etc. Graphical evidence is preferred.

<p>Test 1</p> <p>Voltage = 85% of nominal (195.5 V)</p> <p>Frequency = 47.0 Hz</p> <p>Power factor = 1</p> <p>Period of test 20 seconds</p>	<p>No disconnection occurs</p>
<p>Test 2</p> <p>Voltage = 85% of nominal (195.5 V)</p> <p>Frequency = 47.5 Hz</p> <p>Power factor = 1</p> <p>Period of test 90 minutes</p>	<p>No disconnection occurs</p>
<p>Test 3</p> <p>Voltage = 110% of nominal (253 V).</p> <p>Frequency = 51.5 Hz</p> <p>Power factor = 1</p> <p>Period of test 90 minutes</p>	<p>No disconnection occurs</p>
<p>Test 4</p> <p>Voltage = 110% of nominal (253 V).</p> <p>Frequency = 52.0 Hz</p> <p>Power factor = 1</p> <p>Period of test 15 minutes</p>	<p>No disconnection occurs</p>
<p>Test 5</p> <p>Voltage = 100% of nominal (230 V).</p> <p>Frequency = 50.0 Hz</p>	<p>No disconnection occurs</p>



## ENA Engineering Recommendation G98 Issue 1 – Amendment 7 2022

MATERIALS & SAFETY - R&D

T R 32 89 0

page 3 of 18

Power factor = 1 Period of test 90 minutes	
Test 6 RoCoF withstand  Confirm that the <b>Micro-Generating Plant</b> is capable of staying connected to the <b>Distribution Network</b> and operate at rates of change of frequency up to $1 \text{ Hzs}^{-1}$ as measured over a periode of 500ms.	No disconnection occurs

**Power Quality – Harmonics:** These tests should be carried out as specified in BS EN 61000-3-2. The chosen test should be undertaken with a fixed source of energy at two power levels a) between 45 and 55% and b) at 100% of **Registered Capacity**. The test requirements are specified in Annex A1 A.1.3.1 (**Inverter** connected) or Annex A2 A.2.3.1 (Synchronous).

Micro-generator tested to BS EN 61000-3-2 Phase 1						
Micro-generator rating per phase (rpp)			3,33	kW		
Harmonic	At 45-55% of <b>Registered Capacity</b>		100% of <b>Registered Capacity</b>		Limit in BS EN 61000-3-2 in Amps	Higher limit for odd harmonics 21 and above
	Measured Value MV in Amps		Measured Value MV in Amps			
2	0,010		0,020		1.080	
3	0,060		0,060		2.300	
4	0,010		0,010		0.430	
5	0,060		0,060		1.140	
6	0,000		0,000		0.300	
7	0,060		0,060		0.770	
8	0,000		0,000		0.230	
9	0,050		0,050		0.400	
10	0,000		0,000		0.184	
11	0,060		0,040		0.330	
12	0,000		0,000		0.153	
13	0,030		0,060		0.210	
14	0,010		0,010		0.131	
15	0,050		0,060		0.150	
16	0,010		0,010		0.115	
17	0,040		0,070		0.132	
18	0,010		0,010		0.102	
19	0,010		0,030		0.118	
20	0,000		0,000		0.092	



# ENA Engineering Recommendation G98 Issue 1 – Amendment 7 2022

MATERIALS &amp; SAFETY - R&amp;D

T R 32 89 0

page 5 of 18

21	0,000		0,000		0.107	0.160
----	-------	--	-------	--	-------	-------

22	0,000		0,000		0.084	
23	0,000		0,010		0.098	0.147
24	0,000		0,000		0.077	
25	0,000		0,000		0.090	0.135
26	0,000		0,000		0.071	
27	0,000		0,000		0.083	0.124
28	0,000		0,000		0.066	
29	0,000		0,000		0.078	0.117
30	0,000		0,000		0.061	
31	0,000		0,000		0.073	0.109
32	0,000		0,000		0.058	
33	0,000		0,000		0.068	0.102
34	0,000		0,000		0.054	
35	0,000		0,000		0.064	0.096
36	0,000		0,000		0.051	
37	0,000		0,000		0.061	0.091
38	0,000		0,000		0.048	
39	0,000		0,000		0.058	0.087
40	0,000		0,000		0.046	

Note the higher limits for odd harmonics 21 and above are only allowable under certain conditions, if these higher limits are utilised please state the exemption used as detailed in part 6.2.3.4 of BS EN 61000-3-2 in the box below.

Power Quality – Harmonics: These tests should be carried out as specified in BS EN 61000-3-2. The chosen test should be undertaken with a fixed source of energy at two power levels a) between 45 and 55% and b) at 100% of Registered Capacity. The test requirements are specified in Annex A1 A.1.3.1 (Inverter connected) or Annex A2 A.2.3.1 (Synchronous).						
Micro-generator tested to BS EN 61000-3-2 Phase 2						
Micro-generator rating per phase (rpp)			3,33	kW		
Harmonic	At 45-55% of Registered Capacity		100% of Registered Capacity			
	Measured Value MV in Amps		Measured Value MV in Amps		Limit in BS EN 61000-3-2 in Amps	Higher limit for odd harmonics 21 and above
2	0,010		0,010		1.080	
3	0,000		0,000		2.300	
4	0,000		0,000		0.430	
5	0,010		0,010		1.140	
6	0,000		0,000		0.300	
7	0,010		0,010		0.770	
8	0,000		0,000		0.230	
9	0,010		0,000		0.400	
10	0,000		0,000		0.184	
11	0,020		0,030		0.330	
12	0,000		0,010		0.153	
13	0,010		0,020		0.210	
14	0,010		0,010		0.131	
15	0,020		0,020		0.150	
16	0,010		0,020		0.115	
17	0,020		0,100		0.132	
18	0,010		0,010		0.102	
19	0,010		0,030		0.118	
20	0,000		0,000		0.092	



# **ENA Engineering Recommendation G98** **Issue 1 – Amendment 7 2022**

MATERIALS & SAFETY - R&D

T R 32890

page 7 of 18

21	0,000		0,010		0.107	0.160
----	-------	--	-------	--	-------	-------

22	0,000		0,000		0.084	
23	0,000		0,010		0.098	0.147
24	0,000		0,000		0.077	
25	0,000		0,010		0.090	0.135
26	0,000		0,000		0.071	
27	0,000		0,000		0.083	0.124
28	0,000		0,000		0.066	
29	0,000		0,000		0.078	0.117
30	0,000		0,000		0.061	
31	0,000		0,000		0.073	0.109
32	0,000		0,000		0.058	
33	0,000		0,000		0.068	0.102
34	0,000		0,000		0.054	
35	0,000		0,000		0.064	0.096
36	0,000		0,000		0.051	
37	0,000		0,000		0.061	0.091
38	0,000		0,000		0.048	
39	0,000		0,000		0.058	0.087
40	0,000		0,000		0.046	

Note the higher limits for odd harmonics 21 and above are only allowable under certain conditions, if these higher limits are utilised please state the exemption used as detailed in part 6.2.3.4 of BS EN 61000-3-2 in the box below.

**Power Quality – Harmonics:** These tests should be carried out as specified in BS EN 61000-3-2. The chosen test should be undertaken with a fixed source of energy at two power levels a) between 45 and 55% and b) at 100% of **Registered Capacity**. The test requirements are specified in Annex A1 A.1.3.1 (**Inverter** connected) or Annex A2 A.2.3.1 (Synchronous).

Micro-generator tested to BS EN 61000-3-2 Phase 3						
Micro-generator rating per phase (rpp)			3,33	kW		
Harmonic	At 45-55% of <b>Registered Capacity</b>		100% of <b>Registered Capacity</b>		Limit in BS EN 61000-3-2 in Amps	Higher limit for odd harmonics 21 and above
	Measured Value MV in Amps		Measured Value MV in Amps			
2	0,010		0,010		1.080	
3	0,000		0,000		2.300	
4	0,000		0,000		0.430	
5	0,010		0,010		1.140	
6	0,000		0,000		0.300	
7	0,000		0,000		0.770	
8	0,000		0,000		0.230	
9	0,000		0,010		0.400	
10	0,000		0,000		0.184	
11	0,020		0,040		0.330	
12	0,000		0,000		0.153	
13	0,020		0,050		0.210	
14	0,010		0,010		0.131	
15	0,020		0,020		0.150	
16	0,010		0,010		0.115	
17	0,030		0,070		0.132	
18	0,010		0,010		0.102	
19	0,010		0,020		0.118	
20	0,000		0,000		0.092	





# ENA Engineering Recommendation G98 Issue 1 – Amendment 7 2022

MATERIALS & SAFETY - R&D

T R 32 89 0

page 9 of 18

21	0,000		0,010		0.107	0.160
----	-------	--	-------	--	-------	-------

22	0,000		0,000		0.084	
23	0,000		0,010		0.098	0.147
24	0,000		0,000		0.077	
25	0,000		0,010		0.090	0.135
26	0,000		0,000		0.071	
27	0,000		0,000		0.083	0.124
28	0,000		0,000		0.066	
29	0,000		0,000		0.078	0.117
30	0,000		0,000		0.061	
31	0,000		0,000		0.073	0.109
32	0,000		0,000		0.058	
33	0,000		0,000		0.068	0.102
34	0,000		0,000		0.054	
35	0,000		0,000		0.064	0.096
36	0,000		0,000		0.051	
37	0,000		0,000		0.061	0.091
38	0,000		0,000		0.048	
39	0,000		0,000		0.058	0.087
40	0,000		0,000		0.046	
<p>Note the higher limits for odd harmonics 21 and above are only allowable under certain conditions, if these higher limits are utilised please state the exemption used as detailed in part 6.2.3.4 of BS EN 61000-3-2 in the box below.</p>						

**Power Quality – Voltage fluctuations and Flicker:** These tests should be undertaken in accordance with EREC G98 Annex A1 A.1.3.3 (**Inverter** connected) or Annex A2 A.2.3.3 (**Synchronous**).

The standard test impedance is 0.4  $\Omega$  for a single phase **Micro-generating Plant** (and for a two phase unit in a three phase system) and 0.24  $\Omega$  for a three phase **Micro-generating Plant** (and for a two phase unit in a split phase system). Please ensure that both test and standard impedance are completed on this form. If the test impedance (or the measured impedance) is different to the standard impedance, it must be normalised to the standard impedance as follows (where the Power Factor of the generation output is 0.98 or above):

$d \text{ max normalised value} = (\text{Standard impedance} / \text{Measured impedance}) \times \text{Measured value}.$

Where the **Power Factor** of the output is under 0.98 then the X to R ratio of the test impedance should be close to that of the standard impedance.

The stopping test should be a trip from full load operation.

The duration of these tests needs to comply with the particular requirements set out in the testing notes for the technology under test.

The test date and location must be declared.

The test date and location must be declared.								
Test start date	28.02.2019			Test end date	26.03.2019			
Test location	Upper Austria, Thalheim, Fronius laboratory							
	Starting			Stopping			Running	
	d(max)	d(c)	d(t)	d(max)	d(c)	d(t)	Pst	Plt 2 hours
Measured Values at test impedance	0.97%	2,18%	0	0.97%	2.18%	0	0.265	0.262
Normalised to standard impedance	0.97%	2,18%	0	0.97%	2.18%	0	0.265	0.262
Normalised to required maximum impedance	0.97%	2,18%	0	0.97%	2.18%	0	0.265	0.262
Limits set under BS EN 61000-3-11	4%	3.3%	3.3%	4%	3.3%	3.3%	1.0	0.65
Test Impedance	R	0.24	Ω	X	0.15	Ω		
Standard Impedance	R	0.24 * 0.4^	Ω	X	0.15 * 0.25^	Ω		
Maximum Impedance	R	0.24	Ω	X	0.25	Ω		

\* Applies to three phase and split single phase **Micro-generators**. Delete as appropriate.

^ Applies to single phase **Micro-generators** and **Micro-generators** using two phases on a three phase system. Delete as appropriate.

**Power quality – DC injection:** This test should be carried out in accordance with A 1.3.4 as applicable.

The % DC injection (“as % of rated AC current” below) is calculated as follows:

% DC injection = Recorded DC value in Amps / base current

where the base current is the **Registered Capacity** (W) / 230 V. The % DC injection should not be greater than 0.25%.

Test power level	20%	50%	75%	100%
Recorded DC value in Amps	0.023	0.022	0.029	0.036
as % of rated AC current	0.05	0.05	0.06	0.08
Limit	0.25%	0.25%	0.25%	0.25%

**Power Quality – Power factor:** This test shall be carried out in accordance with A.1.3.2 and A.2.3.2 at three voltage levels and at **Registered Capacity** and the measured **Power Factor** must be greater than 0.95 to pass. Voltage to be maintained within  $\pm 1.5\%$  of the stated level during the test.

	216.2 V	230 V	253 V
Measured value	1.000	1.000	1.000
<b>Power Factor</b> Limit	>0.95	>0.95	>0.95

**Protection – Frequency tests:** These tests should be carried out in accordance with Annex A1 A.1.2.3 (**Inverter** connected) or Annex A2 A.2.2.3 (Synchronous). For trip tests, frequency and time delay should be stated. For “no trip tests”, “no trip” can be stated.

Function	Setting		Trip test		“No trip tests”	
	Frequency	Time delay	Frequency	Time delay	Frequency /time	Confirm no trip
U/F stage 1	47.5Hz	20s	47.50Hz	20.187s	47.7 Hz 30 s	No trip occurred
U/F stage 2	47Hz	0.5s	47.00Hz	0.573s	47.2 Hz 19.5 s	No trip occurred
					46.8 Hz 0.45 s	No trip occurred
O/F stage 1	52Hz	0.5s	52.015Hz	0.582s	51.8 Hz 120.0 s	No trip occurred
					52.2 Hz 0.45 s	No trip occurred

Note. For frequency trip tests the frequency required to trip is the setting  $\pm 0.1$  Hz. In order to measure the time delay a larger deviation than the minimum required to operate the projection can be used. The “No trip tests” need to be carried out at the setting  $\pm 0.2$  Hz and for the relevant times as shown in the table above to ensure that the protection will not trip in error.

**Protection – Voltage tests:** These tests should be carried out in accordance with Annex A1 A.1.2.2 (**Inverter** connected) or Annex A2 A.2.2.2 (Synchronous). For trip tests, voltage and time delay should be stated. For “no trip tests”, “no trip” can be stated.

Phase 1						
Function	Setting		Trip test		“No trip tests”	
	Voltage	Time delay	Voltage	Time delay	Voltage /time	Confirm no trip
U/V	184V	2.5s	184.1V	2.583	188 V 5.0 s	No trip occurred
					180 V 2.45 s	No trip occurred
O/V stage 1	262.2V	1.0s	263.4V	1.021s	258.2 V 5.0 s	No trip occurred
O/V stage 2	273.7V	0.5s	274.6V	0.528s	269.7 V 0.95 s	No trip occurred
					277.7 V 0.45 s	No trip occurred
Note for Voltage tests the Voltage required to trip is the setting $\pm 3.45$ V. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting $\pm 4$ V and for the relevant times as shown in the table above to ensure that the protection will not trip in error.						

**Protection – Voltage tests:** These tests should be carried out in accordance with Annex A1 A.1.2.2 (**Inverter** connected) or Annex A2 A.2.2.2 (Synchronous). For trip tests, voltage and time delay should be stated. For “no trip tests”, “no trip” can be stated.

Phase 2						
Function	Setting		Trip test		“No trip tests”	
	Voltage	Time delay	Voltage	Time delay	Voltage /time	Confirm no trip
U/V	184V	2.5s	184.2V	2.588	188 V 5.0 s	No trip occurred
					180 V 2.45 s	No trip occurred
O/V stage 1	262.2V	1.0s	263.3V	1.024s	258.2 V 5.0 s	No trip occurred
O/V stage 2	273.7V	0.5s	275.1V	0.526s	269.7 V 0.95 s	No trip occurred
					277.7 V 0.45 s	No trip occurred
Note for Voltage tests the Voltage required to trip is the setting $\pm 3.45$ V. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting $\pm 4$ V and for the relevant times as shown in the table above to ensure that the protection will not trip in error.						

**Protection – Voltage tests:** These tests should be carried out in accordance with Annex A1 A.1.2.2 (**Inverter** connected) or Annex A2 A.2.2.2 (Synchronous). For trip tests, voltage and time delay should be stated. For “no trip tests”, “no trip” can be stated.

Phase 3						
Function	Setting		Trip test		“No trip tests”	
	Voltage	Time delay	Voltage	Time delay	Voltage /time	Confirm no trip
U/V	184V	2.5s	184.2V	2.588	188 V 5.0 s	No trip occurred
					180 V 2.45 s	No trip occurred
O/V stage 1	262.2V	1.0s	263.3V	1.024s	258.2 V 5.0 s	No trip occurred
O/V stage 2	273.7V	0.5s	275.1V	0.526s	269.7 V 0.95 s	No trip occurred
					277.7 V 0.45 s	No trip occurred

Note for Voltage tests the Voltage required to trip is the setting  $\pm 3.45$  V. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting  $\pm 4$  V and for the relevant times as shown in the table above to ensure that the protection will not trip in error.

**Protection – Loss of Mains test:** For PV **Inverters** shall be tested in accordance with BS EN 62116. Other **Micro-generators** should be tested in accordance with A.2.2.4 at 10%, 55% and 100% of rated power.

To be carried out at three output power levels with a tolerance of plus or minus 5% in Test Power levels. <sup>9</sup>

Test Power	10%	55%	100%	10%	55%	100%
Balancing load on islanded network	95% of <b>Registered Capacity</b>	95% of <b>Registered Capacity</b>	95% of <b>Registered Capacity</b>	105% of <b>Registered Capacity</b>	105% of <b>Registered Capacity</b>	105% of <b>Registered Capacity</b>
Trip time. Limit is 0.5 seconds						

For Multi phase **Micro-generators** confirm that the device shuts down correctly after the removal of a single fuse as well as operation of all phases.

Test Power	10%	55%	100%	10%	55%	100%
Balancing load on islanded network	95% of <b>Registered Capacity</b>	95% of <b>Registered Capacity</b>	95% of <b>Registered Capacity</b>	105% of <b>Registered Capacity</b>	105% of <b>Registered Capacity</b>	105% of <b>Registered Capacity</b>
Trip time. Ph1 fuse removed	--	--	--	--	--	--

Test Power	10%	55%	100%	10%	55%	100%
Balancing load on islanded network	95% of <b>Registered Capacity</b>	95% of <b>Registered Capacity</b>	95% of <b>Registered Capacity</b>	105% of <b>Registered Capacity</b>	105% of <b>Registered Capacity</b>	105% of <b>Registered Capacity</b>
Trip time. Ph2 fuse removed	--	--	--	--	--	--

Test Power	10%	55%	100%	10%	55%	100%
Balancing load on islanded network	95% of <b>Registered Capacity</b>	95% of <b>Registered Capacity</b>	95% of <b>Registered Capacity</b>	105% of <b>Registered Capacity</b>	105% of <b>Registered Capacity</b>	105% of <b>Registered Capacity</b>
Trip time. Ph3	--	--	--	--	--	--

fuse removed						
Note for technologies which have a substantial shut down time this can be added to the 0.5 s in establishing that the trip occurred in less than 0.5 s. Maximum shut down time could therefore be up to 1.0 s for these technologies.						
Indicate additional shut down time included in above results.					ms	
Additional comments:						
For <b>Inverters</b> tested to BS EN 62116 the following sub set of tests should be recorded in the following table.						
Test Power and imbalance	33% -5% Q Test 22	66% -5% Q Test 12	100% -5% P Test 5	33% +5% Q Test 31	66% +5% Q Test 21	100% +5% P Test 10
Trip Time. Limit is 0.5s	192 ms	176 ms	220 ms	208 ms	180 ms	220 ms

<b>Protection – Frequency change, Vector Shift Stability test:</b> This test should be carried out in accordance with EREC G98 Annex A1 A.1.2.6 ( <b>Inverter</b> connected) or Annex A2 A.2.2.6 (Synchronous). Confirmation is required that the <b>Micro-generating Plant</b> does not trip under positive / negative vector shift.			
	Start Frequency	Change	Confirm no trip
Positive Vector Shift	49.0Hz	+50 degrees	No trip occurred
Negative Vector Shift	50.0Hz	-50 degrees	No trip occurred

<b>Protection – Frequency change, RoCoF Stability test:</b> The requirement is specified in section 11.3, test procedure in Annex A.1.2.6 ( <b>Inverter</b> connected) or Annex A2 A.2.2.6 (Synchronous). Confirmation is required that the Micro-generating Plant does not trip for the duration of the ramp up and ramp down test.			
Ramp range	Test frequency ramp:	Test Duration	Confirm no trip
49.0 Hz to 51.0Hz	+0.95 Hzs <sup>-1</sup>	2.1 s	No trip occurred
51.0 Hz to 49.0Hz	-0.95 Hzs <sup>-1</sup>	2.1 s	No trip occurred

<b>Limited Frequency Sensitive Mode – Overfrequency test:</b> This test should be carried out in accordance with A.1.2.8. The test should be carried out using the specific threshold frequency of 50.4 Hz and Droop of 10%. The measurement tolerances are contained in A.1.2.8.				
Test sequence at <b>Registered Capacity</b> >80%	Measured <b>Active Power</b> Output	Frequency	Primary Power Source	<b>Active Power</b> Gradient
Step a) 50.00 Hz ±0.01 Hz	10026W	50.00Hz	10.2kW	20%/Hz
Step b) 50.45 Hz ±0.05 Hz	9925W	50.45Hz		
Step c) 50.70 Hz ±0.10 Hz	9423W	50.70Hz		
Step d) 51.15 Hz ±0.05 Hz	8538W	51.15Hz		
Step e) 50.70 Hz ±0.10 Hz	9423W	50.70Hz		
Step f) 50.45 Hz ±0.05 Hz	9925W	50.45Hz		

Step g) 50.00 Hz $\pm 0.01$ Hz	10017W	50.00Hz		
Test sequence at <b>Registered Capacity</b> 40% - 60%	Measured <b>Active Power</b> Output	Frequency	Primary Power Source	<b>Active Power Gradient</b>
Step a) 50.00 Hz $\pm 0.01$ Hz	5036W	50.00Hz	5.1kW	20%/Hz
Step b) 50.45 Hz $\pm 0.05$ Hz	4938W	50.45Hz		
Step c) 50.70 Hz $\pm 0.10$ Hz	4435W	50.70Hz		
Step d) 51.15 Hz $\pm 0.05$ Hz	3547W	51.15Hz		
Step e) 50.70 Hz $\pm 0.10$ Hz	4435W	50.70Hz		
Step f) 50.45 Hz $\pm 0.05$ Hz	4938W	50.45Hz		
Step g) 50.00 Hz $\pm 0.01$ Hz	5039W	50.00Hz		

**Power output with falling frequency test:** This test should be carried out in accordance with A.1.2.7.

Test sequence	Measured <b>Active Power</b> Output	Frequency	Primary power source
Test a) 50 Hz $\pm 0.01$ Hz	10161W	50Hz	10.5kW
Test b) Point between 49.5 Hz and 49.6 Hz	10165W	49.55Hz	10.5kW
Test c) Point between 47.5 Hz and 47.6 Hz	10160W	47.55Hz	10.5kW

NOTE: The operating point in Test (b) and (c) shall be maintained for at least 5 minutes

### Re-connection timer.

Test should prove that the reconnection sequence starts after a minimum delay of 20 s for restoration of voltage and frequency to within the stage 1 settings of Table 2. Both the time delay setting and the measured delay should be provided in this form; both should be greater than 20 s to pass. Confirmation should be provided that the Micro-generating Plant does not reconnect at the voltage and frequency settings below; a statement of "no reconnection" can be made.

Time delay setting	Measured delay	Checks on no reconnection when voltage or frequency is brought to just outside stage 1 limits of table 2.			
20.0s	<b>57s</b>	At 266.2V	At 180.0V	At 47.4Hz	At 52.1Hz
Confirmation that the <b>Micro-generator</b> does not re-connect.		No re-connect occurred	No re-connect occurred	No re-connect occurred	No re-connect occurred



<b>Fault level contribution:</b> These tests shall be carried out in accordance with EREC G98 Annex A1 A.1.3.5 ( <b>Inverter</b> connected) and Annex A2 A.2.3.4 (Synchronous). Please complete each entry, even if the fault contribution is zero.					
For machines with electro-magnetic output			For <b>Inverter</b> output		
Parameter	Symbol	Value	Time after fault	Volts	Amps
Peak Short Circuit current	$i_p$	--	20ms	47,22	9,98
Initial Value of aperiodic current	$A$	--	100ms	47,22	9,98
Initial symmetrical short-circuit current*	$I_k$	--	250ms	27,66	0,10
Decaying (aperiodic) component of short circuit current*	$i_{DC}$	--	500ms	27,66	0,09
Reactance/Resistance Ratio of source*	$X/R$	--	Time to trip	0,03	In seconds
For rotating machines and linear piston machines the test should produce a 0 s – 2 s plot of the short circuit current as seen at the <b>Micro-generator</b> terminals.					
* Values for these parameters should be provided where the short circuit duration is sufficiently long to enable interpolation of the plot					

Logic Interface (input port)	
Confirm that an input port is provided and can be used to reduce the <b>Active Power</b> output to zero	Yes
Provide high level description of logic interface, e.g. details in 9.4.3 such as AC or <b>DC</b> signal (the additional comments box below can be used)  The Symo inverter (Power Generating Module) has a S0 connector on the RECERBO print (Display print) which can be used for shutdown and as a logic interface to switch of the inverter. This S0 connector interrupts the inverter feeding energy into the grid if the trigger device (switch) has been activated.	Yes
<b>Self-Monitoring solid state switching:</b> No specified test requirements. Refer to EREC G98 Annex A1 A.1.3.6 ( <b>Inverter</b> connected).	NA
It has been verified that in the event of the solid state switching device failing to disconnect the <b>Micro-generator</b> , the voltage on the output side of the switching device is reduced to a value below 50 V within 0.5 s.	
Note: Unit do not provide solid state switching relays. In case the semiconductor bridge is switched off, then the voltage on the output drops to 0. In this case the relays on the output will also open (functional safety of the internal automatic disconnection device according to VDE 0126-1-1).	
Cyber security	
Confirm that the <b>Manufacturer</b> or <b>Installer</b> of the <b>Micro-generator</b> has provided a statement describing how the <b>Micro-generator</b> has been designed to comply with cyber security requirements, as detailed in 9.7.	Yes
Additional comments	



# ENA Engineering Recommendation G98 Issue 1 – Amendment 7 2022

MATERIALS & SAFETY - R&D

T R 32 89 0

page 18 of 18

