

Certificate of Conformity

Certificate Number: CN-PV-220204

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.


Applicant:	Givenergy Ltd Newspaper House, Chemical Lane, Newcastle Under Lyme, Stoke On Trent, United Kingdom, ST6 4QZ
Product:	PV Hybrid inverter
Ratings & Principle Characteristics:	See appendix of Certificate of Conformity
Model:	HY5.0
Brand Name<s>:	
Product Complies with:	G99 Issue 1 Amendment 8, 1 September 2021 Requirements for the connection of generation equipment in parallel with public distribution networks
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai West Area, 2 nd Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by China National Accreditation Service for Conformity Assessment (CNAS C058-P) in accordance with ISO/IEC 17065:2012
Test Report No.<s>:	220707065GZU-001

Replaces certificate CN-PV-210183 dated 02 August 2021

Certification procedure: SMS-PV-OP-19

Product certification scheme type: Type test

Additional information in Appendix.



Signature

Certification Manager: Grady Ye

Date: 23 September 2022



中国认可
国际互认
产品
PRODUCT
CNAS C058-P

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-220204

Model	HY5.0
Input Date (PV)	
Max. PV array open-circuit Voltage	600Vd.c
Max. total PV array short-circuit circuit	2*20Ad.c
Max. operating PV input current	2*11Ad.c
PV input operating voltage range	120~600Vd.c
MPPT input operating voltage range	120~550Vd.c
Number of independent MPP input	2
Output Date (AC)	
Nominal AC output Power	5000W
AC nominal voltage	230Va.c
AC grid frequency	50Hz
Max. output current	22.8Aa.c
Power factor (Full load)	>0.99
Protect class	I
Backup terminal parameter (AC)	
Nominal AC output Power	3600W
AC nominal voltage	230Va.c
AC grid frequency	50Hz
Max. output current	16Aa.c
Protect class	I
Battery	
Battery Type	Lead-acid or Li-ion
Normal voltage	48V
Operating voltage range	46.7~57.6V
Max. charging current	65Ad.c
Max. discharging current	81Ad.c
Max. charging Power	3600W
Max. discharging Power	3600W

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.