

Certificate of Conformity

Certificate Number: 180802148GZU-001

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. This verification is part of the full test report<s> and should be read in conjunction with it ;

Applicant Name & Address:	JMHing Power Ltd Unit 5 Tower House Lane Industrial Estate, Tower House Lane, Hedon Road, Hull, HU12 8EE, U.K.
Product Description:	Hybrid Inverter
Ratings & Principle Characteristics:	See Annex to Test Certificate of Conformity
Models:	Giv-AC3.0, Giv-AC2.0
Relevant Standards	G98/1-4: 2019, Requirements for the connection of Fully Type Tested Micro-generators (up to and including 16 A per phase) in parallel with public Low Voltage Distribution Networks
Certificate Issuing Office:	Intertek Testing Services Shenzhen Ltd. Guangzhou Branch Block E, No.7-2 Guang Dong Software Science Park, Caipin Road, Guangzhou Science City, GETDD, Guangzhou,
Date of Tests:	China 10 Aug 2019 – 12 Aug 2019
Test Report Number(s):	180802148GZU-001

Additional information in Appendix.

Helen Ma

Signature

Name: Helen Ma
Position: Manager
Date: 31 Aug 2019

This certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Certificate are relevant only to the sample tested/inspected. This Certificate by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program

APPENDIX: Certificate of Conformity

This is an Annex to Certificate of Conformity with Verification/Report Number(s): 180802157GZU-001. The issuing office is Intertek Legal Entity as above.

Ratings and principal characteristics

Model: Giv-AC3.0
 Output/Input Data (AC)
 Nominal AC power: 3000W
 AC Nominal voltage: 230Va.c.
 AC grid frequency:50Hz
 Max.current:14.3Aa.c.
 Power factor : 0.8 Leading ~ 0.8 Lagging
 Backup terminal parameter (AC)
 Nominal AC output power:3000W
 AC nominal voltage:230Va.c,
 AC grid frequency: 50Hz
 Max. output current: 14.3Aa.c
 Battery
 Battery Type: Lead-acid or Li-ion
 Nominal voltage: 48V
 Operating voltage range: 46-58V
 Max. Charging Current: 60Ad.c.
 Max. Discharging Current: 60Ad.c.
 Max. Charging & Discharging Power: 3000W
 Ingress Protection: IP 65
 Protective Class: I
 Operating temperature range: -25 — +60°C
 Software Version: D4-A4

Model: Giv-AC2.0
 Output/Input Data (AC)
 Nominal AC power: 2000W
 AC Nominal voltage: 230Va.c.
 AC grid frequency:50Hz
 Max.current:9.5Aa.c.
 Power factor : 0.8 Leading ~ 0.8 Lagging
 Backup terminal parameter (AC)
 Nominal AC output power:2000W
 AC nominal voltage:230Va.c,
 AC grid frequency: 50Hz
 Max. output current: 9.5Aa.c
 Battery
 Battery Type: Lead-acid or Li-ion
 Nominal voltage: 48V
 Operating voltage range: 46-58V
 Max. Charging Current: 40Ad.c.
 Max. Discharging Current: 40Ad.c.
 Max. Charging & Discharging Power: 2000W
 Ingress Protection: IP 65
 Protective Class: I
 Operating temperature range: -25 — +60°C
 Software Version: D4-A4

This certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Certificate are relevant only to the sample tested/inspected. This Certificate by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program