ENA EREC G99/1-4:2019


Type Test reference number		HMS-1000W-2T, HMS-900W-2T, HMS-800W-2T, HMS-700W-2T, HMS-600W-2T					
Generating Unit technology		Photovoltaic Microinverter					
System Supplier na	System Supplier name		Hoymiles Power Electronics Inc.				
Address		No.18 Kangjing Road, Hangzhou 310015, China					
Tel	+86 571 2805610	1	Fax	-			
Email	info@hoymiles.co	m	Web site	-			
Registered	1.0/0.9/0.8/0.7/0.	kW single n	a phage gingle callit or three phage quater				
Capacity, use	6 per Unit	KVV Sirigle p	W single phase, single, split or three phase system				
separate sheet if	NA	kW three pl	kW three phase				
more than one	NA	kW two phases in three phase system					
connection option.	NA	kW two phases split phase system					


Manufacturer compliance declaration. - I certify that all products supplied by the company with the above Type Tested Manufacturer's reference number will be manufactured and tested to ensure that they perform as stated in this document, prior to shipment to site and that no site Modifications are required to ensure that the product meets all the requirements of EREC G99.


Signed	张岩棚	On behalf of	Hoymiles Power Electronics Inc.
--------	------------	--------------	---------------------------------


Note that testing can be done by the Manufacturer of an individual component or by an external test house.


Where parts of the testing are carried out by persons or organizations other than the Manufacturer then that person or organization shall keep copies of all test records and results supplied to them to verify that the testing has been carried out by people with sufficient technical competency to carry out the tests.























	2. Power Quality - Harmonic Generation									
	Generating Unit tested to BS EN 61000-3-12									
Generating Unit rating per phase (rpp)		1.0 kW		Harmonic % =Measured Value (Amps) x 23/rating per phase (kVA)						
Harmo nic	At 45-55% o	f rated output	100% of ra	ated output		BS EN 0-3-12				
	Measured Value MV in Amps	%	Measured Value MV in Amps	%	1 phase	3 phase				
2	0.0015	0.0345	0.0023	0.0529	8%	8%				
3	0.0054	0.1242	0.0063	0.1449	21.6%	Not stated				
4	0.0012	0.0276	0.0009	0.0207	4%	4%				
5	0.0031	0.0713	0.0025	0.0575	10.7%	10.7%				
6	0.0005	0.0115	0.0007	0.0161	2.67%	2.67%				
7	0.0012	0.0276	0.0018	0.0414	7.2%	7.2%				
8	0.0005	0.0115	0.0006	0.0138	2%	2%				
9	0.0013	0.0299	0.0012	0.0276	3.8%	Not stated				
10	0.0005	0.0115	0.0005	0.0115	1.6%	1.6%				
11	0.0008	0.0184	0.001	0.023	3.1%	3.1%				
12	0.0004	0.0092	0.0002	0.0046	1.33%	1.33%				
13	0.0005	0.0115	0.0006	0.0138	2%	2%				
THD		2.6562		2.8978	23%	13%				
PWHD		4.4799		5.5703	23%	22%				

3. Power Quality. Voltage fluctuations and Flicker

Test to BS EN 61000-3-11								
	Startin	g		Stopping			Running	
	dmax [%]	dc [%]	d(t) [%]	dmax [%]	dc [%]	d(t) [%]	Pst	Plt 2 hours
Measured Values								
at	0.1	0	0	0.1	0	0	0.066	0.066
test impedance								
Normalised to standard impedance	0.1	0	0	0.1	0	0	0.066	0.066
Normalised to								
required maximum	0.1	0	0	0.1	0	0	0.066	0.066
impedance								
Limits set under BS EN 61000-3-11	4%	3.3%	3.3%	4%	3.3%	3.3%	1	0.65
Test impedance	R	0.4		Ω	ΧI	0.25		Ω
Standard	Б	0.24*		Ω	ΧI	0.15* 0.25^		
impedance	R	0.4^		32	λI			Ω
Maximum impedance	R	0.4		Ω	ΧI	0.25		Ω
				Test				
Test start date		2023-07-24		end	2023-07-24			
				date				
Test location		SHANGHAI TESTING & INSPECTION INSTITUTE FOR ELECTRICAL EQUIPMENT CO., LTD.						

4. Power quality. DC injection					
Test power level	10%	55%	100%		
Recorded value(mA)	1.054	3.133	1.895		
as % of rated AC					
current	0.0242	0.0721	0.0436		
Limit	0.25%	0.25%	0.25%		

5. Power Quality. Power factor							
	216.2V	230V	253V	Measured at three voltage levels			
Measured value	0.9989	0.9985	0.9978	and at full output. Voltage to be maintained within ±1.5% of the			
Limit	>0.95	>0.95	>0.95	stated level during the test.			

6. Protection. Frequency tests								
Function	Setting		Trip test		"No trip tests"			
	Fraguenay	Time	Eroguenov	Time	Frequency /time	Confirm		
	Frequency	delay	Frequency	delay	Frequency /time	no trip		
U/F stage 1	47.5Hz	20s	47.5Hz	20.02s	47.7Hz/30s	Confirmed		
U/F stage 2	47Hz	0.5s	47Hz	0.52s	47.2Hz/19.5s	Confirmed		
					46.8Hz/0.45s	Confirmed		
O/F stage 1	52Hz	0.5s	52Hz	0.52s	51.8Hz/120s	Confirmed		
					52.2Hz/0.45s	Confirmed		

	7. Protection. Voltage tests							
Function	Setting		Trip test		"No trip tests"			
	Voltage	Time delay	Voltage	Time delay	Voltage /time	Confirm no trip		
U/V stage 2	184V	2.5s	183.6V	2.52s	188V/5.0s	Confirmed		
					180V/2.45s	Confirmed		
OV stage 1	262.2V	1.0s	262.6V	1.02s	258.2V/5.0s	Confirmed		
O/V stage 2	273.7V	0.5s	274.2V	0.52s	269.7V/0.95s	Confirmed		
					277.7V/0.45s	Confirmed		

8. Power Park Modules - Protection - Loss of Mains test								
Note: Inverter tested according to BS EN 62116.								
Test Power and	33%	66%	100%	33%	66%	100%		
imbalance	-5% Q	-5% Q	-5% P	+5% Q	+5% Q	+5% P		
imbalance	Test 22	Test 12	Test 5	Test 31	Test 21	Test 10		
Trip time. Limit is 0.5s	91.6ms	183.5ms	243.2ms	94.8ms	181.4ms	246.7ms		

9. Loss of Mains Protection, Vector Shift Stability test and RoCoF Stability test								
	Start Frequency	Change	End Frequency	Confirm no trip				
Positive Vector Shift	49.5Hz	+50 degrees		Confirmed				
Negative Vector Shift	50.5Hz	- 50 degrees		Confirmed				
	Ramp range	Test frequency ramp	Test Duration	Confirm no trip				
Positive Frequency drift	49Hz to 51Hz	+0.95Hz/sec	2.1s	Confirmed				
Negative Frequency drift	51Hz to 49Hz	-0.95Hz/sec	2.1s	Confirmed				

10. Limited Frequency Sensitive Mode - Over frequency test							
Active Power resp	onse to rising frequ	ency/time plots are	attached if				
frequency injection	n tests are undertak	en in accordance w	vith Annex A.8.2.4	N			
Test sequence	Measured	Frequency	Primary	Active			
at Registered	Active	(Hz)	Power	Power			
Capacity >80	Power Output		Source	Gradient			
%	(W)						
Step a) 50.00Hz	4005.54	FOLI-		-			
±0.01Hz	1005.54	50Hz					

995.35	50.45		-
046 21	50.7		-
940.21	30.7		
858 66	51 15		-
030.00	31.13		
046.33	50.7		-
940.32	30.1		
005.12	50.45		-
993.12	30.43		
1005.26	50		-
1005.56	50		
Measured	Frequency	Primary	Active
Active	(Hz)	Power	Power
Power Output		Source	Gradient
(W)			
E0E	50		-
505.55	50		
E00 4E	50.45		-
500.45	50.45		
476 AF	50.7		-
470.45	50.7		
422.2	F1 15		-
43∠.3	31.13		
476 10	50.7		-
4/0.12	30.7		
	Active Power Output	946.21 50.7 858.66 51.15 946.32 50.7 995.12 50.45 1005.36 50 Measured Frequency (Hz) Power Output (W) 505.55 50 500.45 50.45 476.45 50.7 432.3 51.15	946.21 50.7 858.66 51.15 946.32 50.7 995.12 50.45 1005.36 50 Measured Active Power Output (W) 505.55 50 500.45 50.45 476.45 50.7 432.3 51.15

11. Protection. Re-connection timer					
Test should prove that the reconnection sequence starts in no less than 20s for restoration					
of voltage and frequency to within the stage 1 settings of table 10.5.7.1					
Time delay	Measured	Checks on no reconnection when voltage or frequency is brought to just outside stage 1 limits of table 10.5.7.1.			frequency is
setting	delay				10.5.7.1.
20.0s	29.4s	At 266.2V	At 180V	At 47.4Hz	At 52.1Hz
Confirmation th	at the				
Generating Unit does not		Confirmed	Confirmed	Confirmed	Confirmed
re-connect.					

12. Fault level contribution					
For machines with electro-magnetic output		For Inverter output			
Parameter	Symbol	Value	Time after fault	Volts	Amps
Peak Short Circuit current	ip	N/A	20ms	19.12V	0.679A
Initial Value of aperiodic	А	N/A	100ms	11.67V	0.235A

current					
Initial symmetrical short-circuit current*	lk	N/A	250ms	9.54V	0.186A
Decaying (aperiodic) component of short circuit current*	iDC	N/A	500ms	5.43V	0.153A
Reactance/Re sistance Ratio of source*	X/R	N/A	Time to trip	0.004s	

For rotating machines and linear piston machines the test should produce a 0s-2s plot of the short circuit current as seen at the Generating Unit terminals.

^{*} Values for these parameters should be provided where the short circuit duration is sufficiently long to enable interpolation of the plot

13. Self-Monitoring solid state switching	Yes/or NA
It has been verified that in the event of the solid-state switching device failing to disconnect the Generating Unit , the voltage on the output side of the switching device is reduced to a value below 50 Volts within 0.5 seconds	N/A

14. Wiring functional tests: If required by para 15.2.1			
Confirm that the relevant test schedule is attached (tests to be undertaken at			
time of commissioning).			

15. Logic interface (input port)	Yes/or NA	
Confirm that an input port is provided and can be used to shut down the	Yes	
module.		