

Certificate of Conformity

Certificate Number: CN-PV-230603

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant: Huawei Digital Power Technologies Co., Ltd.

Office 01, 39th Floor, Block A, Antuoshan Headquarters Towers, 33 Antuoshan

6th Road, Futian District, Shenzhen, 518043, P.R.China.

Product: Solar Inverter & Hybrid Inverter

Ratings & Principle

Characteristics:

See appendix of Certificate of Conformity

Model: SUN2000-12KTL-M5, SUN2000-15KTL-M5, SUN2000-17KTL-M5, SUN2000-

20KTL-M5, SUN2000-25KTL-M5

SUN2000-12K-MB0, SUN2000-15K-MB0, SUN2000-17K-MB0, SUN2000-20K-

MB0, SUN2000-25K-MB0

Brand Name<s>:

HUAWEI

Product Complies with: G99 Issue 1 Amendment 9, 3 October 2022

Requirements for the connection of generation equipment in parallel with

public distribution networks Type approval for Type A

Certificate Issuing Office

Name & Address:

Intertek Testing Services Ltd. Shanghai

West Area, 2nd Floor, No. 707, Zhangyang Road

China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China

Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012

Test Report No.<s>: 231012028GZU-001, 19 Oct 2023

Additional information in Appendix.

Signature

Certification Manager: Grady Ye

/ sud la

Date: 01 November 2023

ACCREDIA T

PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.



APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230603.

Model	SUN2000- 12KTL-M5	SUN2000- 15KTL-M5	SUN2000- 17KTL-M5	SUN2000- 20KTL-M5	SUN2000- 25KTL-M5			
Max. Input voltage	1100Vdc							
MPPT voltage range	200 – 1000Vdc							
Max. MPPT input current	30A*2							
PV Isc	40A*2							
Rated output power	12000W	15000W	17000W	20000W	25000W			
Max. Output power	13200VA	16500VA	18700VA	22000VA	27500VA			
Nominal output voltage	3W/N/PE 230/400Vac							
Max. output current	19.1A	23.9A	27.1A	31.9A	39.9A			
Nominal output frequency	50 Hz							
Power factor range	0.8Leading ~ 0.8Lagging							
Safety level	Class I							
Ingress protection	IP66							
Operation ambient temperature	-25°C - +60°C							
Software version	V200R022							

Remark: Maximum AC output current is based on 230/400 Va.c.

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.



APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230603.

Model	SUN2000-12K-	SUN2000-15K-	SUN2000-17K-	SUN2000-20K-	SUN2000-25K-			
	MB0	MB0	MB0	MB0	MB0			
Max. Input	1100Vdc							
voltage	1100Vdc							
MPPT voltage	200 – 1000Vdc							
range	200 – 1000 vac							
Max. MPPT	30A*2							
input current								
PV Isc	40A*2							
Rated output power	12000W	15000W	17000W	20000W	25000W			
Max. Output power	13200VA	16500VA	18700VA	22000VA	27500VA			
Nominal output voltage	3W/N/PE 230/400Vac							
Max. output current	19.1A	23.9A	27.1A	31.9A	39.9A			
Nominal output frequency	50 Hz							
Battery normal voltage	1		600Vdc		1.			
Battery voltage range	600-980Vdc							
Battery maximum current			26.25Adc*2	\rightarrow				
Battery type	Li-ion							
Power factor								
range	0.8Leading ~ 0.8Lagging							
Safety level	Class I							
Ingress	Incc							
protection			IP66					
Operation								
ambient	-25°C - +60°C							
temperature								
Software	V200R023							
version			. 200025					

Remark: Maximum AC output current is based on 230/400 Va.c.

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.