

Compliance Document

No. D 123231 0004 Rev. 00

Holder of Certificate: **Ruihe (Chongqing) New Energy Technology Co., Ltd.**


Building 7, No.6 Jinchuan Road
Shiban Town, Hi-Tech Zone
401329 Chongqing
PEOPLE'S REPUBLIC OF CHINA

Product: **PV inverter**
Grid-connected Hybrid Inverter

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.: 704092386602-00

Date, 2023-12-04



(Zhengdong Ma)

Compliance Document

No. D 123231 0004 Rev. 00

Model(s): RV4000H-S2, RV5000H-S2, RV6000H-S2

Parameters:

Model	RV4000H-S2	RV5000H-S2	RV6000H-S2
PV input parameters:			
Max. input voltage	d.c. 550 V		
Max. input current	d.c. 2*16 A		
Isc PV (absolute maximum)	d.c. 2*20 A		
MPPT Voltage range	d.c. 40-530 V		
Battery input parameters:			
Battery type	Li-ion		
Rated battery voltage	d.c. 48 V		
Battery voltage range	d.c. 40-60 V		
Max. charge/discharge current	d.c. 100 /100 A		
Grid output parameters:			
Rated grid output active power	4000 W	5000 W	6000 W
Rated grid output apparent Power	4000 VA	5000 VA	6000 VA
Max. grid output apparent Power	4000 VA	5000 VA	6000 VA
Rated output voltage	a.c. 230 V		
Rated output frequency	50 Hz		
Max. output current	a.c. 18.2 A	a.c. 22.7 A	a.c. 27.3 A
Adjustable cos(φ)	0.8ind...0.8cap		

Protection settings (Manufacturer default settings)

Protection Function	Type A Power Generating Modules	
	Trip setting	Time Delay Setting
U/V	$V_{\phi-N} - 20\%$	2.5s
O/V st 1	$V_{\phi-N} + 14\%$	1.0s
O/V st 2	$V_{\phi-N} + 19\%$	0.5s
U/F st 1	47.5 Hz	20s
U/F st 2	47 Hz	0.5s
OF	52 Hz	0.5s
Loss of Mains (RoCoF)	1 Hzs ⁻¹ time delay 0.5 s	

**Tested
according to:**

G99/1-9:2022