

ATTESTATION OF CONFORMITY

Issued to: Sungrow Power Supply Co., Ltd.
No.1699 Xiyou Rd., New & High Technology Industrial Development Zone, 230088,
Hefei, P. R. China

For the product: Grid-connected PV inverter

Trade name: **SUNGROW**

Type/Model: SG250HX

Ratings: PV input: Max. 1500 Vdc, MPPT voltage range: 500-1500 Vdc, max 12*30 A,
Isc PV: 12*50 A
Output: 3/PE, 800 Vac, 50 Hz, Rated output 225 kW, max.250 kVA, max 180.5 A

Manufactured by: Sungrow Power Supply Co., Ltd.
No.1699 Xiyou Rd., New & High Technology Industrial Development Zone, 230088,
Hefei, P. R. China

Requirements: Engineering Recommendation G99 Issue 1 – Amendment 8:2021 (G99/1-8:2021)
(Requirements for Type B, C and D Generating Module)

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 6138292.50V1.1

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 1 March 2023

Number: 6138292.01AOCV1.1

DEKRA Testing and Certification (Shanghai) Ltd.


Kreny Lin
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed