

Certificate of Conformity

By the product certificate number:

No. 230419RECO01A-CER

Issued to

License holder:

Tesla Inc

3500 Deer Creek Road, Palo Alto, California, 94304

Trademark:

TESLA

Factory location:

Tesla Inc

1 Electric Avenue Sparks, NV, USA-89434

It is certified that the product:

Type of generator: **Grid-Connected Converter**

Product Family:

Powerwall 3

Models:

Powerwall 3 1707000-xx-y

Being:

XX = Style code, used to track livery reflecting minor changes that do not affect the products form, fit or function, or product accessory variants,

Y = Pedigree. This identifies process changes, typically invisible to the product.

Technical Data:

Rated Output Power

11.04 kW

Rated Voltage

230 V

Rated Frequency

50 Hz

Firmware Version

gc97c1c548dc5 (or later)

Number Of Phases

Single Phase

Isolation Transformer

No

Is in compliance with the standard:

- **Engineering Recommendation G99. Issue 1, Amendment 9. (3 October 2022) ⁽¹⁾**

Requirements for the connection of generation equipment in parallel with public distribution networks on or after 27 April 2019.

⁽¹⁾ The product above-mentioned is certified to be connected in generation systems of Type A.

This certificate is based upon the test results of the Test Report nº 230419RECO01A. The testing process has been carried out according the SGS internal procedure PE.T-LE-62 based on the requirements of the UNE-EN ISO / IEC 17025.

The above-mentioned generating unit is certified according to the SGS internal process no. 4 based on the requirements of the UNE-EN ISO/IEC 17065.

This certificate is first issued on 15th January 2024.

This certificate is valid until 15th January 2029.

Madrid, 15th January 2024



Daniel Arranz Muñiz
Certification Manager

