

Certificate of Conformity

By the product certificate number

No. 2622/0478-D-CER

Issued to:

License holder:

Victron Energy B.V.
De Paal 35, 1351JG, Almere, Netherlands

Trademark:



It is certified that the product:

Type of product: Inverter/charger with UPS functionality
Family: MultiPlus-II
Tested model: 48/10000/140-100
Variant model: 48/8000/110-100
Technical Data:

	48/8000/110-100	48/10000/140-100
Nominal power:	8 kVA / 6.4 kW	10 kVA / 8 kW
Nominal voltage:	AC input: 187-250 V DC input: 38-66 V (48 V battery) AC output: 220-240 V DC output: 48 V	AC input: 187-250 V DC input: 38-66 V (48 V battery) AC output: 220-240 V DC output: 48 V
Nominal frequency:	50 Hz	50 Hz
Firmware version:	2621502	2627502
Number of phases:	1	1
Isolation Transformer:	Yes	Yes

Is in compliance with the standard:

- **G99/NI Issue 1 (April 2019):** "Requirements for the connection of generation equipment in parallel with public distribution networks in Northern Ireland on or after 27 April 2019"
- **G99 Issue 1 – Amendment 9 (October 2022):** "Requirements for the connection of generation equipment in parallel with public distribution networks on or after 27 April 2019".

The above-mentioned generating unit is certified according to the SGS internal process No. 4 based on the requirements of the UNE-EN ISO / IEC 17065.

This certificate is first issued on 08th June 2023.

This certificate is valid until the 08th June 2028.

Madrid, 08th June 2023

Daniel Arranz Muñiz
Certification Manager

